

2021 Water Quality Report

Town of Bowman

System # 3810004

We're pleased to provide you with this year's Water Quality Report. We want to keep you informed about the water and services we have delivered to you over the past year. Our goal is to provide to you a safe and dependable supply of drinking water. We are committed to ensuring the quality of your water. We purchase water from Orangeburg County. Orangeburg County purchases water from the Town of Santee, and Santee purchases water from Santee Cooper Lake Marion. Our source water is surface water from Lake Marion.

A Source Water Assessment Plan has been prepared for our system. If you have any questions about this report or concerning your water utility, please contact Yvonne Lewis at (803)829-2666. We want you, our neighbors and valued customers, to be informed about your water utility. Feel free to attend any of our regularly scheduled meetings on the first Tuesday of every month at 7:00 pm at the Bowman Town Hall located at 131 Poplar Street. The public is encouraged to attend.

This report shows our water quality and what it means. The Town of Bowman routinely monitors for constituents in your drinking water according to Federal and State laws. As water travels over the land or underground, it can pick up substances or contaminants such as microbes and chemicals. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

The table below shows the results of our monitoring for the period of January 1st to December 31st, 2021. In this table you will find the following terms and abbreviations:

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

WATER DATA TABLE

Town of Bowman #3810004

Lead and Copper – Inorganic Contaminants

Contaminants (unit of measure)	ALG	AL	90 th percentile	# Samples Exceeding AL	Exceeds AL (Yes/No)	Sample Date	Typical Source
Copper-action level at consumer taps (ppm)	1.3	1.3	0.43	0	No	2020	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead-action level at consumer taps (ppb)	0	15	2.7	1	No	2020	Corrosion of household plumbing systems. Erosion of natural deposits.

Disinfectant and Disinfection By-Products

Contaminants (unit of measure)	MCLG or MRDLG	MCL, TT, or MRDL	Detect in Your Water	Range	Violation (Yes or No)	Sample Date	Typical Source
Chlorine (ppm)	4	4	0.0 RAA	0.1 – 0.9	No	2021	Water additive used to control microbes
HAAs [Haloacetic Acids] (HAA5) (ppb)	No goal for the total	60	1 LRAA	0 – 2.46	No	2021	By-product of drinking water chlorination.
TTHMs [Total Trihalomethanes] (ppb)	No goal for the total	80	2 LRAA	0 – 1.8	No	2021	By-product of drinking water disinfection.

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform of E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample.	1		0	N	Naturally present in the environment.

Chemical Constituents for surface water from Santee Cooper Lake Marion Regional Water Plant (SC3820003)

Contaminants (unit of measure)	MCLG or MRDLG	MCL, TT, or MRDL	Detect in Your Water	Range	Violation (Yes or No)	Sample Date	Typical Source
Nitrate (ppm)	10	10	0.45	0.45 – 0.45	No	2021	Runoff from fertilizer use. Erosion of natural deposits.
Sodium (ppm)	NA	NA	14	14 – 14	No	2021	Naturally occurring.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

If you have special health needs--

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Bowman is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

